



Removal of dissolved and colloidal matter from surface waters by composite flocculant aluminum salt-sodium alginate

Abdellah-Anouar El Foulani^{a,b,*}, Omar Ounas^{a,b}, Anass Laabi^{b,c}, Brahim Lekhlif^b, Jamal Jamal-Eddine^a

^aLaboratory of Organic Synthesis, Extraction and Valorisation, Faculty of Sciences Ain Chock, Hassan II University, B.P 5366, Oasis, Casablanca, Morocco, Tel. +212 618 23 32 47; emails: elfoulanianouar@gmail.com (A.-A. El Foulani), o.ounas@gmail.com (O. Ounas), jj_edd@yahoo.fr (J. Jamal-Eddine)

^bResearch Team Hydrogeology, Water Treatment and Climate Change, Environmental Engineering Laboratory, Hassania School of Public Works, B.P 8108 Oasis Casablanca, Morocco, emails: laabianass@yahoo.fr (A. Laabi), lekhelif.brahim@ehp.ac.ma (B. Lekhlif)

^cHigher National School of Mechanics and Electricity, Hassan II University, B.P 8118, Oasis Casablanca, Morocco

Received 12 February 2020; Accepted 25 July 2020

ABSTRACT

Colloidal matter present in the surface water is an undesirable element that must be treated appropriately to make the water drinkable. The most commonly used process is coagulation–flocculation, followed by sand filtration to obtain excellent water quality with a turbidity limit value not exceeding 0.5 NTU. Despite the effectiveness obtained by this process, the reagents used poses problems in terms of their residual concentrations after treatment. This study focused on the removal of dissolved and colloidal matter from surface waters, used as a source for drinking water, by using a composite flocculant consisting of aluminum salt and sodium alginate. The tests were carried out on the waters taken from the Sidi Saïd Maâchou dam located on the Oum Er-Rbia River in Morocco, whose turbidity was adjusted to 100 NTU and permanganate index of 7.16 mgO₂ L⁻¹ that involved the organic matter. For the composite flocculant, tests showed 98% elimination of turbidity and 36% of organic substances for a dose of 4 mg L⁻¹ of aluminum and 1.6 mg L⁻¹ of sodium alginate. In contrast to the conventional method, it expends the aluminum six times more to achieve a reduction rate of 90% of turbidity and 28% of organic substances with a slight increase in conductivity. Several operating parameters were optimized to reduce the treatment cost.

Keywords: Coagulation; Flocculation; Composite flocculant; Dam water; Water treatment

1. Introduction

With socio-economic and demographic development, the need for drinking water is increasing. The available water resources are subject to various sources of pollution; thus affecting their quality and requiring appropriate treatment. The most commonly used process to remove colloidal contamination is coagulation–flocculation because of its simplicity and effectiveness in removing turbidity, color

and some contaminants [1,2]. In recent years, this process has improved in terms of the reagents nature, including inorganic flocculants, organic flocculants and composite flocculants. However, composite flocculants are increasingly used in water treatment because of their superior efficiency over traditional inorganic flocculants and their low cost compared to organic flocculants [3].

Conventional coagulation–flocculation is carried out in two steps. The first one is called coagulation. It consists of

* Corresponding author.

destabilizing the suspended particles using commonly aluminum- or Iron-based metal coagulants [4,5]. The second one is called flocculation. It consists of aggregating the particles formed during the destabilization of the suspended matter into large agglomerates that can easily be separated by settling. The flocculants or flocculation adjuvants are in their majority, polymers of very high molecular weight. They can be mineral, natural organic or synthetic organic in nature. Synthetic chemical flocculants remain the most widely used due to their cost-effectiveness and high efficiency. However, in line with health and environmental concerns, their use has become limited. In that regard, bio-flocculants present great importance for health and ease of biodegradation, as well as their environmentally-friendly behavior [6]. Bioflocculants are natural organic substances having a macromolecular size. They are able to flocculate colloidal matter and suspended solids [7]. These macromolecules commonly contain backbones of polysaccharides, proteins and nucleic acids [8]. The main sources of these macromolecular substances are algae, fungi, bacteria and actinobacteria [9]. The limitation of the direct application of these bioflocculants is related to low yield of production and high-cost [10]. Alternatively, composite flocculants containing a mixture of inorganic flocculant and bioflocculant can overcome individual flocculant defects by increasing treatment efficiency and dewaterability of the sludge [11–13]. Among these bioflocculants, alginate is a linear polysaccharide block copolymer extracted from the cell walls of brown algae, which includes the 1,4-bonded β -D-mannuronic acid and α -L-guluronic acid residues [14]. This anionic biopolymer is widely used in pharmaceutical and food industry. Also, the alginate is used in water treatment as a flocculant to accelerate the rate of aggregate formation [15,16].

This study aims to compare the removal efficiency of colloidal suspension by aluminum salts and sodium alginate using conventional coagulation–flocculation and composite flocculant. The different operating parameters were optimized to improve the coagulation process with the composite flocculant. The process performance was monitored by using turbidity, conductivity, hardness, pH, permanganate index and Fourier-transform infrared (FTIR) spectroscopy.

2. Materials and methods

2.1. Preparation of reconstituted solutions

The tests were carried out on reconstituted solutions prepared in the laboratory by water taken from the Sidi Saïd Maâchou dam (Fig. 1), located at the mouth of the Oum Er-Rbia River (Morocco) and soil from the same location. The soil-water mixture was left to settle for 2 h to remove coarse matter. Then the supernatant had undergone several adjustments to obtain a reconstituted solution with the desired turbidity.

2.2. Preparation of composite flocculant

A stock solution of composite flocculant was prepared by dissolving a 5/2 ratio of Al/OH in 250 mL of distilled water. The solution contains 11.18 g of aluminum chloride hexahydrate ($\text{AlCl}_3 \cdot 6\text{H}_2\text{O}$) and 0.5 g mass of sodium alginate was




Fig. 1. Geographical location satellite image of the Sidi Saïd Maâchou dam (Google Earth).

stirred at low speed for 24 h before treatment to ensure better homogenization.

2.3. Coagulation–flocculation tests


The coagulation–flocculation tests were carried out on the solutions reconstituted in a jar-test model JF/6 Isco Milan Italy at six posts. Three series of experiments were conducted. In the first series, conventional coagulation–flocculation was performed on 500 mL volume solutions at a speed of 250 rpm for 3 min (coagulation), and at a speed of 25 rpm for 20 min (flocculation). After a 30 min settling time, the supernatant is recovered for analysis.

In the second series, the composite flocculant was added to reconstituted solutions. The tests were carried out under the same conditions as the first series.

The third series was established to optimize the treatment parameters'. These parameters are alternated varied one by one while maintaining the other constants. These parameters are coagulant rate, flocculant rate, rapid agitation time, rapid agitation rate, slow agitation time, agitation rate, and settling time.


2.4. pH adjustment

The aluminum ion (Al^{3+}) in aqueous solution hydrolyzes to form many entities such as hydrolyzed monomer and polymer complexes: $\text{Al}(\text{OH})^{2+}$, $\text{Al}(\text{OH})_2^+$, $\text{Al}(\text{OH})_4^-$, $\text{Al}_6(\text{OH})_{15}^{3+}$, $\text{Al}_7(\text{OH})_{17}^{4+}$, $\text{Al}_8(\text{OH})_{20}^{4+}$, etc. and release protons according to the following reaction:



These entities promote electrostatic coagulation due to their positive charges. When $\text{pH} \geq 4$, the hydrolyzed complex of the polynuclear structure $\text{Al}_{13}(\text{O})_4(\text{OH})_{24}^{7+}$ gives $\text{Al}(\text{OH})_3$ by precipitation and polymers [17,18]. Those can contribute to the removal by adsorption of soluble organic compounds and suspended matter.

To avoid excessive acidification and to further promote coagulation by adsorption, pH adjustment was performed by adding caustic soda (NaOH) at a concentration of 0.1 M. The following formula calculates the quantities of NaOH added:



where [OH] is the hydroxide mass concentration; M(OH) is the hydroxide molar mass; [Al] is the aluminum mass concentration; M(Al) is the aluminum molar mass.

2.5. Parameters and measurement methods

During our tests, turbidity, conductivity, hardness, pH, and permanganate index parameters were monitored. The sample turbidity was measured in a nephelometric turbidity unit (NTU) using a Palintest 7000 photometer (Palintest Limited, Tyne & Wear, UK). The pH and the temperature were measured using a multi-parameter digital device Hach HQ40d (Hach Company, Loveland, Colorado, USA). pH was monitored before and after treatment, while the solution temperature fluctuated around 20°C–23°C throughout the entire operational period. The sample conductivity was measured by an Orion conductivity meter, model 125. The water hardness was measured using the ethylenediaminetetraacetic acid volumetric titration method (NF T 90-003/1984). The concentration of organic matter in solutions was determined by the permanganate index (PI) according to standard method NF T 90-050. The flocculants were characterized using a Fourier-transform infrared FTIR spectrophotometer (JASCO FT/IR-4600, Japan) in the wavelengths range of 1,850 to 1,350 cm⁻¹.

3. Results and discussions

3.1. Conventional coagulation–flocculation test

A series of conventional coagulation–flocculation tests were carried out by adding coagulant (AlCl₃·6H₂O) followed by the flocculant (sodium alginate).

The turbidity was decreased with a fixed alginate concentration of 1.6 mg L⁻¹ and an increased dose of Al³⁺, as shown in Fig. 2a. For an optimal dose of 25 mg L⁻¹ of aluminum, the turbidity reduction reached 90% accompanied by the removal of 28% of the organic matter (Table 1). This reduction in the colloidal suspension is due to the mechanism involved between the particle and the coagulant Al³⁺: complexing between the soluble hydrolyzed forms of aluminum and the colloidal matter, and/or adsorption on the solid aluminum hydroxide flocs Al(OH)₃. Nevertheless, pH around neutrality presents the optimal range for the removal of mineral and organic matter. The coagulation, in this optimal range, is done preferably by adsorption on aluminum hydroxide flocs Al(OH)₃ with an acidic Lewis character; thus allowing it to fix the negatively charged suspended matter, and also the dissolved matter [19–21]. Indeed, the long-chain structure and high molecular weight of alginate promote the adsorption and bridging of colloids or Al-colloid. Their numerous –COO– and –OH sites increase coagulation efficiency and accelerate the sedimentation rate [22]. The improvement of colloid removal by charge neutralization effect is a suggestion that has been abandoned due to the negative charge of alginate [23]. In this process, firstly, the negatively charged colloidal suspension was destabilized by the action of positively charged aluminum monomers and/or polymers, forming small Al-colloid flocs. Secondly, the alginate was added to convert the small flocs formed in the previous step into larger flocs by adsorption and bridging.

However, during the process, pH decreases until it stabilizes around 7 (Fig. 2b), due to the release of Al³⁺ in solution. The conductivity, meanwhile, increases with the dose of the coagulant (Table 1), but this increase remains in small proportions. The presence of AlCl₃ (123.5 mg L⁻¹) and NaOH (47 mg L⁻¹) was expected to result in a substantial increase in the conductivity via their ions, but this is not the case as shown in Fig. 3. This could be explained by the formation in addition to Al(OH)₃ other solid compounds including sodium and chlorides in their structures, and/or the absorption of part of the chlorides on the Al(OH)₃ flocs directly or




Fig. 2. (a) Evolution of turbidity for conventional coagulation–flocculation and (b) evolution of pH for conventional coagulation–flocculation.

Table 1
Result of treatment by conventional coagulation–flocculation with 25 mg L⁻¹ aluminum and 1.6 mg L⁻¹ sodium alginate

Parameters	Solution before treatment	Solution after treatment
Turbidity (NTU)	100	10
pH	7.6	6.97
Conductivity (mS cm ⁻¹)	2.93	3.13
Permanganate index (mgO ₂ L ⁻¹)	7.16	5.12
Total hardness (°F)	35	32.6




Fig. 3. Conductivity evolution for solutions without and with pH adjustment.




Fig. 4. Evolution of turbidity for composite flocculant.

in combination with the clay sheets through metal bridges [24–26].

The total hardness decreases (Table 1) due to the contribution of calcium and magnesium in the formation of insoluble compounds with the suspended matter by two mechanisms. The first one is the formation of direct insoluble form between cations and suspended matter that can result in sedimentation. The second one is the incorporation of cations in the binding between suspended solids and aluminum hydroxide. It results in the formation of a bridge between these two species [27].

3.2. Coagulation–flocculation test using a composite flocculant

The tests on the composite flocculant (aluminum–alginate complex) were conducted to be compared with the conventional method.

These tests showed higher turbidity removal, which reaches a level of 98% (Fig. 4) by using doses of 4 mg L⁻¹ and 1.6 mg L⁻¹ for coagulant and flocculant, respectively. Contrary to the composite flocculant, the conventional method gives a 90% reduction rate with coagulant quantities six-time more (Fig. 2a). Concerning dissolved organic matter, there is a 36% reduction for composite flocculant (Table 2) compared to 28% for conventional coagulation–flocculation (Table 1). For the conductivity, it increases but remains low compared to coagulation–flocculation tests. Despite the addition of NaOH for pH adjustment,

Table 2
Treatment results by composite flocculant with 4 and 1.6 mg L⁻¹ respectively of aluminum and sodium alginate

Parameters	Solution before treatment	Solution after treatment
Turbidity (NTU)	100	2
pH	7.74	7.16
Conductivity (mS cm ⁻¹)	2.92	2.96
Permanganate index (mgO ₂ L ⁻¹)	7.16	4.56
Total hardness (°F)	35	32.6

the conductivity increases by 1.3% compared to 6.8% for conventional coagulation–flocculation. This is due to the minimum amount of reagents consumed for the abatement of the colloidal suspension. In addition, the decrease in total hardness reveals the contribution of the constituent elements of this parameter (calcium, magnesium) to the destabilization of colloidal particles [28]. A similar evolution was documented by Xia et al. [29] during a comparison between poly-aluminum ferric chloride (PAFC) and the inorganic organic-type composite flocculant. The composite flocculant was composed of anionic microbial bioflocculant, *Klebsiella Variicola* B16 and PAFC. They observed that the incorporation of PAFC into the anionic bioflocculant

(consisting mainly of the polysaccharide), had reduced the concentration of PAFC by 58% compared to the use of PAFC alone for an initial turbidity 100 NTU. Indeed, the addition of a composite flocculant containing a mass of 10.5 mg L⁻¹ of PAFC and 4.5 mg L⁻¹ of *Klebsiella Variicola* B16 allowed 95% of turbidity reduction efficiency.

The improvement in the efficiency of coagulation with composite flocculant can be explained by the combination of AlCl₃ and polymer Alginate, providing a high molecular weight material on which the coagulant is anchored, synergizing coagulation and flocculation. This system allows the removal of colloidal suspensions by absorption on colloid-Al-alginate or colloid-Al-alginate-Al-colloid chains. In this order, the analysis of composite flocculant by FTIR spectroscopy has shown the displacement of the carboxylic group, which presents the key to the sorption of the metal by the alginate acid (Fig. 5). The characteristic bands obtained by FTIR are a strong asymmetrical stretching and a slightly weaker symmetrical stretching vibration COO– [30,31]. However, the variation between these two peaks ($\Delta\nu = \text{CO}_{\text{asym}} - \text{CO}_{\text{sym}}$) reflects the carboxylate structure with metal by comparison with the variation of sodium alginate peaks [31]. In fact, the $\Delta\nu$ (COO–) value of Al³⁺ is lower than that of Na⁺, which shows that the coordination between aluminum and alginate sodium takes place via bidentate chelation.

These results are similar to those found in the literature [32,33]; they have shown that the new generation of coagulants (composite flocculant) is significantly more effective than the conventional one. Thus, reducing the effect of pH and improving the removal of suspended solids with a minimum concentration of aluminum.

3.3. Optimization of operating parameters for composite flocculant

The optimization results of the operating parameters are represented in Table 3:

These tests made the optimization of the operating settings possible with the composite flocculant in the




Fig. 5. FTIR spectra of the sodium alginate and aluminum-alginate complexes in the region of 1,350–1,850 cm⁻¹.

coagulation–flocculation process. The results are due to the enhanced coagulation. It improves coagulation and aggregation, resulting in a compact and less voluminous sludge compared to the conventional method which accelerates sedimentation [34,35].

3.4. Cost treatment study

An economic study was established based on the results obtained after optimization of the operating parameters. This study includes all the changes implemented.

3.4.1. Expression of cost

The operating cost per meter cube (m³) of treatment with the composite flocculant is the sum of the electrical energy value consumed and the reagents used during treatment.

$$\begin{aligned} \text{Treatment cost (USD} \cdot \text{m}^{-3}) &= \sum \text{Unit Price (USD} \cdot \text{m}^{-3}) \\ &= \sum \text{Consumption in m}^3 \cdot \text{Sale Price} \end{aligned} \quad (3)$$

The power is calculated by the relation, which is valid in the case where the agitation is mechanical [36].

$$P = 1/2 \times C_t \times A \times \rho \times V_r^3 \quad (4)$$

where P is the power dissipated in the liquid (W); C_t is the drag coefficient (it is equal to 1.8 for flat blades); A is the blade surface (m²); ρ is the liquid density (kg m⁻³); V_r is the blade relative speed in respect to the liquid speed surrounding it, approximately 0.75 \times peripheral blade speed (V_p):

$$V_p = 2 \times \pi \times d \times N / 60 \quad (5)$$

where d represents the distance from the blade tip to the axis of rotation (m) and N is the number of agitation (min).

The processing cost was calculated (Table 4) by using all the charges involved in Eqs. (3)–(5). The electric energy price corresponds to the last tranche (consumption > 500 kWh). This tranche has a higher price. It's delivered by Lyonnaise des Eaux de Casablanca (LYDEC) to the industrial sector located in the Greater Casablanca Region, Morocco. For reagents, the price used is that of the international element costs per ton.

Table 3
Optimised coagulation–flocculation parameters with a composite flocculant

Test 1	Aluminum mass (mg L ⁻¹)	4
Test 2	Sodium alginate mass (mg L ⁻¹)	1.2
Test 3	Fast stirring time (min)	1
Test 4	Fast stirring speed (tours min ⁻¹)	100
Test 5	Slow stirring time (min)	9
Test 6	Slow stirring speed (tours min ⁻¹)	25
Test 7	Settling time (min)	20

Table 4
Treatment cost calculation

	Reagents used			Energy consumed
	Sodium alginate	AlCl ₃	NaOH	
Sales price in USD	12.000/ton [37]	540/ton [38]	220/ton [39]	0.16633 kWh m ⁻³ [40]
Consumption × 10 ⁻³	1.6 kg m ⁻³	35.77 kg m ⁻³	17.778 kg m ⁻³	128.7746 kWh m ⁻³
Unit price (USD m ⁻³)	0.0192	0.0193	0.0039	0.021419
Drinking water treatment costs: 0.0638 USD m ⁻³				

The use of composite flocculant for surface water treatment seems effective. It minimizes the concentration of reagents and the energy dissipated during the agitation by increasing the aggregation capacity. The aggregation capacity accelerates sedimentation leading to an operating cost of 0.0638 USD m⁻³. All these imply in the perfection of purification by the advanced method. These results are in accordance with those found in the literature [41,42], which have proven the economic and environmental benefits of composite flocculant. The results in the literature suggest that the composite flocculant can replace the conventional coagulants for the removal of colloidal suspension from water. Regardless of the bioflocculant high price in the meantime, the competitiveness of bioflocculant-based composite flocculants is increasing by the second. This competitiveness is increasing due to the fact that the price of this bioflocculant is steadily declining thanks to the high demand for this type of polymer to industrialize.

4. Conclusions

Our study explored a new generation of coagulation reagents made by a composite flocculant, resulting from the incorporation of inorganic materials (AlCl₃, 6H₂O) in a natural organic polymer (sodium alginate). The results obtained indicate that the coupling of coagulant-flocculant is more effective than their use separately in terms of the colloidal suspension reduction and through the reagents consumed. For initial turbidity of 100 NTU and 7.16 mgO₂ L⁻¹ in the permanganate index that implies organic matter. The composite flocculant containing 4 mg L⁻¹ of aluminum and 1.2 mg L⁻¹ sodium alginate reduced 98% of the turbidity and 36% of the dissolved organic matter. The rapid agitation rate (coagulation) was 100 rpm for 1 min, and the slow agitation rate (flocculation) was 25 rpm for 10 min. The settling time was 20 min. All these optimized parameters had the effect of reducing the treatment cost.

References

- [1] J.-L. Lin, C. Huang, B. Dempsey, J.-Y. Hu, Fate of hydrolyzed Al species in humic acid coagulation, *Water Res.*, 56 (2014) 314–324.
- [2] J. Dotto, M.R. Fagundes-Klen, M.T. Veit, S.M. Palácio, R. Bergamasco, Performance of different coagulants in the coagulation/flocculation process of textile wastewater, *J. Cleaner Prod.*, 208 (2019) 656–665.
- [3] J. Ma, R. Wang, X.Y. Wang, H. Zhang, B. Zhu, L.L. Lian, D.W. Lou, Drinking water treatment by stepwise flocculation using polysilicate aluminum magnesium and cationic polyacrylamide, *J. Environ. Chem. Eng.*, 7 (2019) 103049.
- [4] M. Rebosura, S. Salehin, I. Pikaar, J. Kulandaivelu, G. Jiang, J. Keller, K. Sharma, Z. Yuan, Effects of in-sewer dosing of iron-rich drinking water sludge on wastewater collection and treatment systems, *Water Res.*, 171 (2020) 115396.
- [5] E.C. Lopes, S.C.R. Santos, A.M.A. Pintor, R.A.R. Boaventura, C.M.S. Botelho, Evaluation of a tannin-based coagulant on the decolorization of synthetic effluents, *J. Environ. Chem. Eng.*, 7 (2019) 103125.
- [6] P.F. Sun, H. Lin, G. Wang, L.L. Lu, Y.H. Zhao, Preparation of a new-style composite containing a key bioflocculant produced by *Pseudomonas aeruginosa* ZJU1 and its flocculating effect on harmful algal blooms, *J. Hazard. Mater.*, 284 (2015) 215–221.
- [7] E. Lichtfouse, N. Morin-Crini, M. Fourmentin, H. Zemmouri, I.O.C. do Nascimento, L.M. Queiroz, M.Y.M. Tadza, L.A. Picos-Corrales, H. Pei, L.D. Wilson, Chitosan for Direct Bioflocculation Processes, G. Crini, E. Lichtfouse, Eds., *Sustainable Agriculture Reviews*, Vol. 36, Springer, Cham, 2019, pp. 335–380.
- [8] H.P. Guo, C.T. Hong, B.S. Zheng, F. Lu, D. Jiang, W.S. Qin, Bioflocculants' production in a biomass-degrading bacterium using untreated corn stover as carbon source and use of bioflocculants for microalgae harvest, *Biotechnol. Biofuels*, 10 (2017) 1–12.
- [9] P. Sivasankar, S. Poongodi, A.O. Lobo, A. Pugazhendhi, Characterization of a novel polymeric bioflocculant from marine actinobacterium *Streptomyces* sp. and its application in recovery of microalgae, *Int. Biodeterior. Biodegrad.*, 148 (2020) 104883.
- [10] L.L. Ma, J.J. Liang, S. Wang, B. Yang, M.Y. Chen, Y.C. Liu, Production of a bioflocculant from *Klebsiella* sp. OS-1 using brewery wastewater as a source, *Environ. Technol. (United Kingdom)*, 40 (2019) 44–52.
- [11] Z.H. Yang, J. Huang, G.M. Zeng, M. Ruan, C.S. Zhou, L. Li, Z.G. Rong, Optimization of flocculation conditions for kaolin suspension using the composite flocculant of MBFGA1 and PAC by response surface methodology, *Bioresour. Technol.*, 100 (2009) 4233–4239.
- [12] F. Ni, X.J. Peng, J.S. He, L. Yu, J. Zhao, Z.K. Luan, Preparation and characterization of composite bioflocculants in comparison with dual-coagulants for the treatment of kaolin suspension, *Chem. Eng. J.*, 213 (2012) 195–202.
- [13] J.Y. Guo, C. Chen, Sludge conditioning using the composite of a bioflocculant and PAC for enhancement in dewaterability, *Chemosphere*, 185 (2017) 277–283.
- [14] L. Ramirez, S.R. Gentile, S. Zimmermann, S. Stoll, Comparative study of the effect of aluminum chloride, sodium alginate and chitosan on the coagulation of polystyrene micro-plastic particles, *J. Colloid Sci. Biotechnol.*, 5 (2016) 190–198.
- [15] P.S.P. Batista, A.M.M.B. de Morais, M.M.E. Pintado, R.M.S.C. de Morais, *Alginate: Pharmaceutical and Medical Applications*, Springer, Cham, 2019, pp. 649–691.
- [16] Y.X. Zhao, Y. Wang, B.Y. Gao, H.K. Shon, J. Kim, Q.Y. Yue, Coagulation performance evaluation of sodium alginate used as coagulant aid with aluminum sulfate, iron chloride and titanium tetrachloride, *Desalination*, 299 (2012) 79–88.
- [17] M.L. Cabiguen, A.N. Soriano, A.P. Adornado, Reduction of water hardness from groundwater in Puerto Princesa City, Palawan, Philippines using electrocoagulation, *IOP Conf. Ser.: Earth Environ. Sci.*, 191 (2018) 012029.

- [18] F. Zidane, P. Drogui, B. Lekhlif, J. Bensaid, Decolorization of dye-containing effluent using mineral coagulants produced by electrocoagulation, *J. Hazard. Mater.*, 155 (2008) 153–163.
- [19] Z.G. Liu, X. Lu, J.K. Xie, B. Feng, Q.N. Han, Synthesis of a novel tunable lignin-based star copolymer and its flocculation performance in the treatment of kaolin suspension, *Sep. Purif. Technol.*, 210 (2019) 355–363.
- [20] C.Z. Hu, S.Q. Wang, J.Q. Sun, H.J. Liu, J.H. Qu, An effective method for improving electrocoagulation process: optimization of Al_{13} polymer formation, *Colloids Surf., A*, 489 (2016) 234–240.
- [21] W.Z. Yu, L. Xu, K. Lei, J. Gregory, Effect of crystallization of settled aluminum hydroxide precipitate on “dissolved Al”, *Water Res.*, 143 (2018) 346–354.
- [22] S. Thakur, S. Pandey, O.A. Arotiba, Development of a sodium alginate-based organic/inorganic superabsorbent composite hydrogel for adsorption of methylene blue, *Carbohydr. Polym.*, 153 (2016) 34–46.
- [23] S. Wang, X. Huang, M. Elimelech, Complexation between dissolved silica and alginate molecules: implications for reverse osmosis membrane fouling, *J. Membr. Sci.*, 605 (2020) 118109.
- [24] T. Cao, I. Szilagyi, T. Oncsik, M. Borkovec, G. Trefalt, Aggregation of colloidal particles in the presence of multivalent co-ions: the inverse Schulze–Hardy Rule, *Langmuir*, 31 (2015) 6610–6614.
- [25] N. Gongor, S. Dilmac, Difference in the influence of Na and Ca ions on the zeta potentials of anatolian Bentonitic Clays, *J. Inclusion Phenom. Mol. Recognit. Chem.*, 26 (1996) 93–101.
- [26] W.-J. Lee, S.-II. Pyun, Effects of hydroxide ion addition on anodic dissolution of pure aluminum in chloride ion-containing solution, *Electrochim. Acta*, 44 (1999) 4041–4049.
- [27] R. Sudoh, M.S. Islam, K. Sazawa, T. Okazaki, N. Hata, S. Taguchi, H. Kuramitz, Removal of dissolved humic acid from water by coagulation method using polyaluminum chloride (PAC) with calcium carbonate as neutralizer and coagulant aid, *J. Environ. Chem. Eng.*, 3 (2015) 770–774.
- [28] B. Bina, M.H. Mehdinejad, M. Nikaeen, H.M. Attar, Effectiveness of chitosan as natural coagulant aid in treating turbid waters, *Iran. J. Environ. Health Sci. Eng.*, 6 (2009) 247–252.
- [29] X. Xia, S.H. Lan, X.D. Li, Y.F. Xie, Y.J. Liang, P.H. Yan, Z.Y. Chen, Y.X. Xing, Characterization and coagulation–flocculation performance of a composite flocculant in high-turbidity drinking water treatment, *Chemosphere*, 206 (2018) 701–708.
- [30] Q. Xiao, X. Gu, S. Tan, Drying process of sodium alginate films studied by two-dimensional correlation ATR-FTIR spectroscopy, *Food Chem.*, 164 (2014) 179–184.
- [31] S.K. Papageorgiou, E.P. Kouvelos, E.P. Favvas, A.A. Sapalidis, G.E. Romanos, F.K. Katsaros, Metal-carboxylate interactions in metal-alginate complexes studied with FTIR spectroscopy, *Carbohydr. Res.*, 345 (2010) 469–473.
- [32] B.-Y. Gao, Y. Wang, Q.-Y. Yue, J.-C. Wei, Q. Li, Color removal from simulated dye water and actual textile wastewater using a composite coagulant prepared by polyferric chloride and polydimethyldiallylammonium chloride, *Sep. Purif. Technol.*, 54 (2007) 157–163.
- [33] Y. Wang, B. Gao, Q.Y. Yue, J.C. Wei, Q. Li, The characterization and flocculation efficiency of composite flocculant iron salts–polydimethyldiallylammonium chloride, *Chem. Eng. J.*, 142 (2008) 175–181.
- [34] Z.L. Yang, X.X. Liu, W.Z. Zhao, S. Zhao, Y. Wang, Q.Y. Yue, Q. Li, Flocculation kinetics and floc characteristics of dye wastewater by polyferric chloride–poly-epichlorohydrin–dimethylamine composite flocculant, *Sep. Purif. Technol.*, 118 (2013) 583–590.
- [35] X.X. Li, Y.J. Zhang, X.L. Zhao, N. Gao, T. Fu, The Characteristics of sludge from enhanced coagulation processes using PAC/PDMDAAC composite coagulants in treatment of micro-polluted raw water, *Sep. Purif. Technol.*, 147 (2015) 125–131.
- [36] M.J. Brandt, K.M. Johnson, A.J. Elphinston, D.D. Ratnayaka, Chapter 8 – Storage, Clarification and Chemical Treatment, M.J. Brandt, K.M. Johnson, A.J. Elphinston, D.D. Ratnayaka, Eds., *Tworts Water Supply*, 7th ed., Butterworth-Heinemann, Boston, USA, 2017, <https://doi.org/10.1016/b978-0-08-100025-0.00008-9>.
- [37] S.W.K. van den Burg, A.P. van Duijin, H. Bartelings, M.M. van Krimpen, M. Poelman, The economic feasibility of seaweed production in the North Sea, *Aquacult. Econ. Manage.*, 20 (2016) 235–252.
- [38] M. Schwiderski, A. Kruse, Process design and economics of an aluminum chloride catalyzed organosolv process, *Biomass Convers. Biorefin.*, 6 (2016) 335–345.
- [39] D. Donaldson, B. Raahauge, *Essential Readings in Light Metals*, Vol. 1, Alumina and Bauxite, Springer, Switzerland, 2017, p. 1169.
- [40] Tranches de facturation et tarifs, (n.d.). Available at: <https://client.lydec.ma/site/fr/tranches-de-facturation-et-tarifs-pro> (accessed February 13, 2020)
- [41] C.Y. Hu, S.L. Lo, C.L. Chang, F.L. Chen, Y. De Wu, J.L. Ma, Treatment of highly turbid water using chitosan and aluminum salts, *Sep. Purif. Technol.*, 104 (2013) 322–326.
- [42] C.Y. Chen, C.Y. Wu, Y.C. Chung, The coagulation characteristics of humic acid by using acid-soluble chitosan, water-soluble chitosan, and chitosan coagulant mixtures, *Environ. Technol. (United Kingdom)*, 36 (2015) 1141–1146.